

# Island County Water Well Information



**WellKey: 4WX**

## General Information

Owner Name (log): South Maxwelton Beach Water Sys. (no log)

DOE Tag:

DOE NOI:

DOE ID

Well Address:

Well Parcel: [R32808-510-4620](#)


Served Parcel:

Horiz/Vert Accuracy: Site Plan / DEM

Site Type: Well



[Click to View  
Well Location in  
Google Maps](#)



[Click to View  
Well Location in  
Google Earth](#)

SWI Rating: Medium Risk

## Construction Information

Construction Date:

Driller Name: Unknown

LS Elevation: 8 ft. MSL

Depth Well:

TD Elevation: -89 ft. MSL

WL Measurements: No measurements available

WL Elevation:

No Scanned  
Water Well  
Report Available

## Water Quality Information

Water Samples: [22 samples \(Click to View\)](#)


Average/Median/Maximum Arsenic:

Average/Median/Maximum Chloride: 8.68 / 8.7 / 9.1 mg/l

Average/Median/Maximum Hardness:

Average/Median/Maximum Nitrate: 0.19 / 0.225 / 0.25 mg/l

Bacteria Samples (distribution): [56 samples \(Click to View\)](#)



## Public Water System Information

Pws Name: South Maxwelton Beach Water System

PwsID: [15051](#)

Approved Connects: 0

Pws Source #: SO# 1

Pws Source Name: Well #1 AKY725

Note: Underlined items in **bright blue** are hyperlinks to additional information / resources.

Questions? Contact the [Island County Hydrogeologist](#), or visit the [Hydrogeology Web Page](#).

Report Generated: 12/30/2020